


Declaration of Compliance



Panelboard Series

Contents:

- Generic Compliance Declaration
- AS/NZS 61439 D1 Design Verification Table
- Specification
- Associated Test reports

The purpose of this document is to assist Installation Assemblers to prepare documentation for Design Verification of switchboards while using B&R supplied enclosures and accessories.

This document does not in itself imply complete AS/NZS 61439 compliance.

Document Created: 09 June 2021
Document Number

B&R Enclosures – Panelboard Series Statement of Compliance

B&R Enclosures Pty Ltd, located at 51 Stradbroke Street, Heathwood, QLD 4110, hereby declares that our electrical power distribution boards, known as the Panelboard Series, conform to the specifications outlined in AS/NZS 3000:2018, along with pertinent sections of AS/NZS 61439 Part 3 where applicable, when assembled in strict accordance with the manufacturer's instructions.

These products are manufactured in conformity with following relevant Standards:

AS/NZS 3000:2018	Electrical installations (known as the Wiring Rules)
AS/NZS 61439.3:2016	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO) (IEC 61439-3, Ed. 2.0 (2011), MOD)
AS/NZS 60529	Degrees of protection provided by enclosures (IP Code)

Our products are manufactured within our manufacturing plants to best practice of Quality, Safety and Environmental standards demonstrated through accreditation to:

ISO 9001:2015	Quality management system
ISO 14001:2015	Environmental management system
AS/NZS 4801:2001	Occupational health & safety management system



Barry Walker
Research and Compliance Officer - Product Development
B&R Enclosures



	Characteristic to be verified	Clauses	Status/by	Compliance
1	Strength of material and parts	10.2		
1a	Resistance to corrosion	10.2.2	Compliant	The resistance to corrosion was tested using a representative sample. Plus ES report; 103687.
1b	Thermal stability	10.2.3.1	N/A	This clause refers mainly to plastic enclosures.
1c	Resistance to abnormal heat & fire due to internal electric effects.	10.2.3.2	Compliant	All insulating materials supplied have been tested to 960°C glow-wire Standard. TÜVRheinland report 50233558 006.
1d	Resistance to ultra-violet (UV) radiation	10.2.4	Compliant	UV ratings refer mainly to plastic enclosures however metal Powder-coat painted enclosures incorporates UV stabilization. AksoNobel report; 20LSR178
1e	Lifting	10.2.5	N/A	Lifting is verified by test, if required . Generally, this relates to larger switchboards to which lifting means (lugs) have been provided.
1f	Mechanical impact	10.2.6	Compliant	IK10; Metal enclosure systems have been tested to exceed IK10 (20 Joules).
1g	Marking	10.2.7	Assembler	Markings must be verified by test. Tests are performed by rubbing with water and petroleum spirits; generally done by the Switchboard Builder (Assembler).
2	Degree of Protection	10.3	Compliant	IP33/IP66; Ingress Protection (IP) rating needs to be verified by test or by assessment. SIMTARS report; NE13/0052
3	Clearances	10.4	Compliant	Clearance and creepage can only be verified by test. Switchboard Builders (Assembler) must maintain compliance by ensuring correct clearance and creepage distances are maintained at >8mm ($U_{imp}=6kV$).
4	Creepage distances	10.4	Compliant	
5	Protection against electric shock and integrity of protective circuits:	10.5		
5a	Effective continuity between the exposed conductive parts of the ASSEMBLY and the protective circuit.	10.5.2	Compliant	Equipotential protective earth bonding points are required to be verified by test to less than 0.1ohm. Similar enclosure designs have been tested by Plus ES report; 103687
5b	Short-circuit withstand strength of the protective circuit	10.5.3	Compliant	The Panelboard Series are generally understood to be fitted with equipment making the switchboard not exceed 10kA prospective short-circuit withstand rating. Chassis has been tested independently to 25kA for 0.1s, see TÜV Rheinland report 19301651 003
6	Incorporation of switching devices and components		Assembler	Points 6, 7 and 8 are largely the responsibility of the Switchboard builder (Assembler). It is a requirement that the Assembler follow guidance from the original manufacturer. The advice of original manufacturers such as B&R and switchgear manufacturers, needs to be adhered to. Switchboard Builders need to be aware of the Standard's requirements for these verification points and incorporate these into complete design verification documentation.
7	Internal electrical circuits and connections		Assembler	
8	Terminals for external conductors		Assembler	
9	Dielectric properties:	10.9		
9a	Power-frequency withstand voltage	10.9.2	Compliant	The Panelboard Series of enclosures are provided as a basic empty enclosure with an MCB chassis provided. Power-frequency type testing has been conducted at U_{imp} 6kV. See TÜV Rheinland report 19301651 001.
9b	Impulse withstand voltage	10.9.3		
10	Temperature-rise limits	10.1	Designer or Assembler	Temperature-rise can be determined by test or by comparison or by calculation. The Panelboard Series of enclosures are rated to a maximum of 250A and therefore AS/NZS 60890 should be used at a rated diversity factor of no more than 80% (see specification sheet).
11	Short-circuit withstand strength	10.11	Compliant	The Panelboard Series are generally understood to be fitted with equipment making the switchboard not exceed 10kA prospective short-circuit withstand rating. Chassis has been tested independently to 25kA for 0.1s, see TÜV Rheinland report 19301651 003.
12	Electromagnetic compatibility (EMC)	10.12	Assembler	Equipment installed in switchboards shall comply with the immunity requirements of the relevant product or generic EMC standard. The Switchboard builder (assembler) shall obtain from the device and or component manufacturer the specific performance criteria of the equipment based on the acceptance criteria given in the relevant standard.
13	Mechanical operation	10.13	Assembler	This verification testing need NOT be done on devices already been type tested according to their relevant product standard. Only if their mechanical operation has been modified does the assembly need to be retested by cycling it 200 times.

Notes

Switchboard Builders are also recommended to study other requirements of the Standard which are not listed here such as parts of section 8 for Constructional Requirements (check clauses 8.4 and 8.5)
 TÜV Rheinland, Plus ES and SIMTARS are the trademarks of independent NATA certified external laboratories

Definitions

TBD	Either the Assembler needs to conduct these tests or B&R needs to be asked for advice.
Exempt	Switchboards that having a rated short-time withstand current (I_{cw}) or rated conditional short-circuit current (I_{cc}) not exceeding 10kARMS or; Switchboards protected by upstream current-limiting devices with a let-through current not exceeding 17kA with the maximum allowable prospective short-circuit current (I_{cp}) at the terminals of the incoming circuit of the switchboard.



Panelboard Series

Specification Sheet

	Econo	Superior	
Degree of Protection (IP code)	IP33	IP66	
Rated operational voltage (U _e)	230/400	230/400	V
Rated voltage (U _n)	415	415	V
Rated insulation voltage (U _i)	440	440	V
Rated impulse withstand voltage (U _{imp})	6	6	kV
Over Voltage category	IV	IV	Distribution cct level
DBO type	B	B	
Power frequency withstand voltage	2	2	kV
Rated current of the ASSEMBLY (I _{nA})	250	250	A
Rated current of a circuit (I _{nc})	63	63	A
Rated peak withstand current (I _{pk})	52	52	kA
Rated short-time withstand current (I _{cw})	10	10	kA (1s)
Rated conditional short-circuit current (I _{cc})	25	25	kA (0.1s)
Rated frequency (f _n)	50	50	Hz
Pollution degree	3	3	
Mechanical impact protection	IK07	IK10	
Clearance	> 14	> 14	mm
Creepage	> 14	> 14	mm
Protective circuit	< 50	< 50	mΩ
Material thickness	1	1.6	mm
Earthing system	Earth bar on each side equipotential bonded to enclosure		
Neutral system	Neutral bar each side with busbar bridge between left and right bars		
Rated diversity factor (RDF)	outgoing circuits	Assumed loading	
	2-3	0.8	
	4-5	0.7	
	6-9	0.6	
	>10	0.5	

Important Notices:

- Modifying the panelboard beyond B&R Enclosures' design scope or installation instructions makes the user the 'Assembly Manufacturer' and thereby responsible for compliance to AS/NZS 61439.3.
- Avoid installing the panelboard in areas with volatile/corrosive elements. Consider stainless board for coastal/corrosive settings.
- Assess the environment for extra protection needs, for example potential condensation. If required use a breathing/pressure equalization valve IP/VP12 or consider anti-condensation heaters (as per AS/NZS 3000:2018 section 1.7.2.).

Certificate
 Of Verification Tests
 Number 103687

Apparatus 2280 A, IP66, 415 V / 800 V / 8kV (Ue/Uj/Uimp) 50 Hz, power switchgear and controlgear (PSC) assembly incorporating three-phase and neutral, horizontal and vertical busbar systems, an incoming ACB unit with CT chamber compartment, an outgoing ACB unit and six outgoing MCCB units and a protective circuit. The PSC-assembly is suitable for outdoor use and has a metallic enclosure.

Designation Monarch 3000 LV Main Switchboard
Vendor B & R Enclosures Pty Ltd
 Brisbane South Industrial Park, 51 Stradbroke Street,
 Heathwood, QLD, 4110, Australia

Dates of Tests 26 September 2017 to 28 November 2018
 The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to a series of proving tests in accordance with:

AS/NZS 61439.2 : 2016
 The results are shown in the Test Record and the oscillograms attached hereto. The values obtained, and the general performance are considered to comply with the above standard and to justify the rating assigned by the manufacturer as stated below.

Verifications with reference to the tests listed in AS/NZS 61439.1 : 2016 Annex D:

- | | |
|--------------------------------------|--------------------------------------|
| 1: Strength of materials and parts | 9: Dielectric properties |
| 2: Degree of protection | 10: Temperature-rise |
| 3: Clearances | 11: Short-circuit withstand strength |
| 4: Creepage distances | 12: EMC compatibility |
| 5: Protection against electric shock | 13: Mechanical operation |
- 6/7/8: no verification by testing required
 See pages 1, 2, 3 and 4 for full details of ratings assigned by the manufacturer and proven by test.

The Test Record applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the manufacturer. Only reproduction of this entire document or reproduction of this page accompanied by the pages on which are stated the assigned rated characteristics of the apparatus tested are permitted without written permission from PLUS ES, 18 Mars Road, Lane Cove West, NSW, 2066, Australia.
 Telephone: 61 (0)2 9424 3600, Facsimile: 61 (0)2 9428 2545.
 This Certificate comprises this front sheet, 88 pages incorporating 4 ratings pages, 2 diagrams, 41 oscillograms, 94 photographs and 12 drawings.



M. A. Carstedt
 M. A. Carstedt
 Authorised Signatory
 Manager - LCTS
 11/3/2020
 Date of Issue

NATA Accredited for compliance with ISO / IEC 17025. Accreditation Number 62. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Test Report No.: 50233558 006	Page 1 of 5 Seite 1 von 5																
Client: Nylec Product Pty Ltd Auftraggeber: 125 Merrindale Drive, Croydon South VIC 3136, Australia																	
Test item: 3 phase distribution chassis Gegenstand der Prüfung:																	
Identification: ENC250-24 Bezeichnung:	Serial No.: N/A Serien-Nr.:																
Receipt No.: 252100149 Wareneingang-Nr.:	Date of receipt: 2019-04-19 Eingangsdatum:																
Condition of test item at delivery: New item, no damage visible Zustand des Prüfgegenstandes bei Anlieferung:																	
Testing location: TÜV Rheinland Australia Pty. Ltd. Prüfart: 182 Dougharty Road, Heidelberg West, Australia VIC 3081																	
Test specification: Thermal Stability test according to clause 10.2.3.1 of AS/NZS 61439.1:2016 for verification of the Assembly. Prüfgrundlage:																	
Test Result: The test item passed the test specifications. Prüfergebnis: Der vorstehend beschriebene Prüfgegenstand wurde geprüft und entspricht oben genannter Prüfgrundlage.																	
Testing Laboratory: TÜV Rheinland Australia Pty. Ltd. Prüflaboratorium: 182 Dougharty Road, Heidelberg West, Australia VIC 3081																	
Compiled by / zusammengestellt: Gergo Bogdan Reviewed by / kontrolliert: Antony K Milovac																	
Date: 2019-05-29 Name: Gergo Bogdan Signature: [Signature]	Date: 2019-05-29 Name: Antony K Milovac Signature: [Signature]																
Other Aspects/ Sonstiges: Main Busbar rated current 250 A Number of Poles 24																	
*More details on the second page																	
<table border="0"> <tr> <td>Abkürzungen:</td> <td>P(ass) = entspricht Prüfgrundlage</td> <td>Abkürzungen:</td> <td>P(ass) = passed</td> </tr> <tr> <td>F(ail)</td> <td>= entspricht nicht Prüfgrundlage</td> <td>F(ail)</td> <td>= failed</td> </tr> <tr> <td>N/A</td> <td>= nicht anwendbar</td> <td>N/A</td> <td>= not applicable</td> </tr> <tr> <td>N/T</td> <td>= nicht getestet</td> <td>N/T</td> <td>= not tested</td> </tr> </table>		Abkürzungen:	P(ass) = entspricht Prüfgrundlage	Abkürzungen:	P(ass) = passed	F(ail)	= entspricht nicht Prüfgrundlage	F(ail)	= failed	N/A	= nicht anwendbar	N/A	= not applicable	N/T	= nicht getestet	N/T	= not tested
Abkürzungen:	P(ass) = entspricht Prüfgrundlage	Abkürzungen:	P(ass) = passed														
F(ail)	= entspricht nicht Prüfgrundlage	F(ail)	= failed														
N/A	= nicht anwendbar	N/A	= not applicable														
N/T	= nicht getestet	N/T	= not tested														
This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products. Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugswise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfteilsens.																	

Accredited for compliance with ISO/IEC 17025 Technical Competence
 IAC-MRA NATA
 Revision 5.0

Test Report No.: 19301651 003	Page 1 of 22 Seite 1 von 22																
Client: Nylec Products, 125 Merrindale Drive, South Croydon, VIC 3136, Australia																	
Test item: ENC250-36-DF encapsulated chassis in an enclosure Gegenstand der Prüfung:																	
Identification: Drawing No. ENC250-XX_DF Bezeichnung: (as sent by client)	Serial No.: Serien-Nr.:																
Receipt No.: 1113007473 Wareneingang-Nr.:	Date of receipt: Eingangsdatum:																
Condition of test item at delivery: New item Zustand des Prüfgegenstandes bei Anlieferung:																	
Testing location: TÜV Rheinland Australia Pty. Ltd. Prüfart: 182 Dougharty Road, Heidelberg West, Australia VIC 3081																	
Test specification: Testing limited to relevant clauses of IEC 61439-1 Ed. 2.0 and IEC 61439-2 Ed. 2.0 Prüfgrundlage:																	
Test Result: Refer results herein Prüfergebnis:																	
Testing Laboratory: TÜV Rheinland Australia Pty. Ltd. Prüflaboratorium: 182 Dougharty Road, Heidelberg West, Australia VIC 3081																	
Compiled by / zusammengestellt: John Strugarek Reviewed by / kontrolliert: Antony K. Milovac																	
Date: 04-02-2015 Name: John Strugarek Signature: [Signature]	Date: 04-02-2015 Name: Antony K. Milovac Signature: [Signature]																
Other Aspects/ Sonstiges: Tests were performed according to Clause 10.11																	
<table border="0"> <tr> <td>Busbars:</td> <td>2.0 mm thick copper</td> </tr> <tr> <td>Rated current of the ASSEMBLY (I_{na}):</td> <td>250 A</td> </tr> <tr> <td>Rated frequency:</td> <td>50 Hz</td> </tr> <tr> <td>Rated voltage (U_n):</td> <td>415 V</td> </tr> <tr> <td>Rated insulation voltage (U_i):</td> <td>440 V</td> </tr> <tr> <td>Rated short-time withstand current (I_{sw}):</td> <td>10 kA for 1.0 s, 25 kA for 0.1 s</td> </tr> <tr> <td>Rated peak withstand current (I_{pk}):</td> <td>52.5 kA</td> </tr> </table>		Busbars:	2.0 mm thick copper	Rated current of the ASSEMBLY (I _{na}):	250 A	Rated frequency:	50 Hz	Rated voltage (U _n):	415 V	Rated insulation voltage (U _i):	440 V	Rated short-time withstand current (I _{sw}):	10 kA for 1.0 s, 25 kA for 0.1 s	Rated peak withstand current (I _{pk}):	52.5 kA		
Busbars:	2.0 mm thick copper																
Rated current of the ASSEMBLY (I _{na}):	250 A																
Rated frequency:	50 Hz																
Rated voltage (U _n):	415 V																
Rated insulation voltage (U _i):	440 V																
Rated short-time withstand current (I _{sw}):	10 kA for 1.0 s, 25 kA for 0.1 s																
Rated peak withstand current (I _{pk}):	52.5 kA																
Tests also satisfy the relevant requirements of AS/NZS 3439.1																	
<table border="0"> <tr> <td>Abkürzungen:</td> <td>P(ass) = passed</td> <td>Abkürzungen:</td> <td>P(ass) = passed</td> </tr> <tr> <td>F(ail)</td> <td>= failed</td> <td>F(ail)</td> <td>= failed</td> </tr> <tr> <td>N/A</td> <td>= not applicable</td> <td>N/A</td> <td>= not applicable</td> </tr> <tr> <td>N/T</td> <td>= not tested</td> <td>N/T</td> <td>= not tested</td> </tr> </table>		Abkürzungen:	P(ass) = passed	Abkürzungen:	P(ass) = passed	F(ail)	= failed	F(ail)	= failed	N/A	= not applicable	N/A	= not applicable	N/T	= not tested	N/T	= not tested
Abkürzungen:	P(ass) = passed	Abkürzungen:	P(ass) = passed														
F(ail)	= failed	F(ail)	= failed														
N/A	= not applicable	N/A	= not applicable														
N/T	= not tested	N/T	= not tested														
This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products. Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugswise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfteilsens.																	

Accredited for compliance with ISO/IEC 17025 Technical Competence
 IAC-MRA NATA
 Revision 5.0

Test Report No.: 19301651 001	Page 1 of 23 Seite 1 von 23																
Client: Nylec Products, 125 Merrindale Drive, South Croydon, VIC 3136, Australia																	
Test item: ENC250-36-DF encapsulated chassis in an enclosure Gegenstand der Prüfung:																	
Identification: Drawing No. ENC250-XX_DF Bezeichnung: (as sent by client)	Serial No.: N/A Serien-Nr.:																
Receipt No.: 1113007473 Wareneingang-Nr.:	Date of receipt: 14-11-2014 Eingangsdatum:																
Condition of test item at delivery: New item Zustand des Prüfgegenstandes bei Anlieferung:																	
Testing location: TÜV Rheinland Australia Pty. Ltd. Prüfart: 182 Dougharty Road, Heidelberg West, Australia VIC 3081																	
Test specification: Testing limited to relevant clauses of IEC 61439-1 Ed. 2.0 and IEC 61439-2 Ed. 2.0 Prüfgrundlage:																	
Test Result: Refer results herein Prüfergebnis:																	
Testing Laboratory: TÜV Rheinland Australia Pty. Ltd. Prüflaboratorium: 182 Dougharty Road, Heidelberg West, Australia VIC 3081																	
Compiled by / zusammengestellt: John Strugarek Reviewed by / kontrolliert: Antony K. Milovac																	
Date: 04-02-2015 Name: John Strugarek Signature: [Signature]	Date: 04-02-2015 Name: Antony K. Milovac Signature: [Signature]																
Other Aspects/ Sonstiges: Tests were performed according to Clause 10.4, Clause 10.9 and Clause 10.10.2.3.7 a) and d)																	
<table border="0"> <tr> <td>Busbars:</td> <td>2.0 mm thick copper</td> </tr> <tr> <td>Rated current of the ASSEMBLY (I_{na}):</td> <td>250 A</td> </tr> <tr> <td>Rated current of a circuit (I_{nc}):</td> <td>63 A</td> </tr> <tr> <td>Rated diversity factor:</td> <td>0.8</td> </tr> <tr> <td>Rated frequency:</td> <td>50 Hz</td> </tr> <tr> <td>Rated voltage (U_n):</td> <td>415 V</td> </tr> <tr> <td>Rated insulation voltage (U_i):</td> <td>440 V</td> </tr> <tr> <td>Rated impulse withstand voltage (U_{imp}):</td> <td>6 kV</td> </tr> </table>		Busbars:	2.0 mm thick copper	Rated current of the ASSEMBLY (I _{na}):	250 A	Rated current of a circuit (I _{nc}):	63 A	Rated diversity factor:	0.8	Rated frequency:	50 Hz	Rated voltage (U _n):	415 V	Rated insulation voltage (U _i):	440 V	Rated impulse withstand voltage (U _{imp}):	6 kV
Busbars:	2.0 mm thick copper																
Rated current of the ASSEMBLY (I _{na}):	250 A																
Rated current of a circuit (I _{nc}):	63 A																
Rated diversity factor:	0.8																
Rated frequency:	50 Hz																
Rated voltage (U _n):	415 V																
Rated insulation voltage (U _i):	440 V																
Rated impulse withstand voltage (U _{imp}):	6 kV																
Tests also satisfy the relevant requirements of AS/NZS 3439.1																	
<table border="0"> <tr> <td>Abkürzungen:</td> <td>P(ass) = passed</td> <td>Abkürzungen:</td> <td>P(ass) = entspricht Prüfgrundlage</td> </tr> <tr> <td>F(ail)</td> <td>= failed</td> <td>F(ail)</td> <td>= entspricht nicht Prüfgrundlage</td> </tr> <tr> <td>N/A</td> <td>= not applicable</td> <td>N/A</td> <td>= nicht anwendbar</td> </tr> <tr> <td>N/T</td> <td>= not tested</td> <td>N/T</td> <td>= nicht getestet</td> </tr> </table>		Abkürzungen:	P(ass) = passed	Abkürzungen:	P(ass) = entspricht Prüfgrundlage	F(ail)	= failed	F(ail)	= entspricht nicht Prüfgrundlage	N/A	= not applicable	N/A	= nicht anwendbar	N/T	= not tested	N/T	= nicht getestet
Abkürzungen:	P(ass) = passed	Abkürzungen:	P(ass) = entspricht Prüfgrundlage														
F(ail)	= failed	F(ail)	= entspricht nicht Prüfgrundlage														
N/A	= not applicable	N/A	= nicht anwendbar														
N/T	= not tested	N/T	= nicht getestet														
This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products. Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugswise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfteilsens.																	

Accredited for compliance with ISO/IEC 17025 Technical Competence
 IAC-MRA NATA
 Revision 5.0

